

Questions and Answers for Vader- Enchanted Valley Reservoir

Q: For the existing reservoir on page 2 sec. 09 97 14, E. 4 says to waterjet clean the interior and exterior. For the interior are we only to clean the area that the paint will be damaged by welding or the entire reservoir?

A: The contractor is to clean only the areas where work is happening

Q: Will the county be cleaning the sediment out of the tank after draining or will that be the contractor's job?

A: We would like the contractor to clean out any sediment out of the reservoir while they are in there. We do not anticipate much if any sediment to be present, as it is currently a potable water tank and has been cleaned fairly recently.