

**Lewis County's Responses to Questions During Advertisement for the
Garrard Crk Rd MP 2.8 Long Term Scour Repair Project
Federal Aid Project No. ER-2023(002)
CRP No. 2159P**

[Notice Addendum No. 1 dated August 9, 2023](#)

Addendum No. 1 has been issued to delay Bid Submittal requirement and Bid Opening until August 17, 2023. Please review this information posted on Lewis County's website [[CallForBids - Garrard Creek Rd. MP 2.8 Long Term Scour Repair Project Details \(lewiscountywa.gov\)](#)] and provide acknowledgement of Addendum No. 1 on the Proposal Signature Page when submitting your Bid for this project.

Contractor Questions and [LC Answers](#)
From Bid Call through August 9, 2023

1. Q: Will there be a pre-bid meeting and are the construction limits staked?
A: The Garrard Crk. MP 2.8 Long Term Scour Repair Project will not have a pre-bid meeting. The approximate stream construction and guardrail limits were staked in the field on 7-Aug-23.

2. Q: What is the timing for construction that you have in mind? The HPA shows that in water work below the OHWL has to be completed by 8/31.

A: Special Provision Section 1-07.5(2) states "...Contractor may begin Work below the Ordinary High Water Line on ***July 1*** and must complete all Work by ***September 30***." The HPA has been extend to match these listed dates. Construction is intended to start as soon as the Contract is executed (Notice to Proceed within 7 calendar days of Contract execution per Special Provision Section 1-08.4) with all in-water completed by September 30, 2023.

[Additional Information regarding the WDFW HPA](#)

All environmental permit requirements listed in the Contract Plans and Special Provisions remain unchanged (excluding the August 31 in-water work limitation). The project's WDFW HPA 2023-5-33+01 has been approved for a Minor Modification (in-water work extended until **September 30**). This document is available for review on Lewis County's website [[CallForBids - Garrard Creek Rd. MP 2.8 Long Term Scour Repair Project Details \(lewiscountywa.gov\)](#)]. Note, additional monitoring requirements (for salmonids and lamprey holding below the work area after August 31) associated with this in-water work time extension will be completed by Lewis County Environmental staff members. This HPA Minor Modification document is informational only and not part of an addendum.